

ADDENDUM NO. 6

CITY OF SAN ANTONIO
AVIATION DEPARTMENT

PROJECT NAME: **San Antonio International Airport IT Infrastructure Modernization**

DATE: February 06, 2012

ADDENDUM NO. 6

This addendum shall be included in, and be considered a part of the plans and specifications for the above named project. The contractor shall be required to sign an Acknowledgment of the receipt of this Addendum, in the form attached hereto as Attachment A to Addendum No.6, and submit the Acknowledgement with their bid.

AVIATION PROJECT NO.: 33-00048

A. SPECIFICATIONS REVISIONS

- *CHANGE:* Section 13 34 23 FABRICATED STRUCTURES, Part 2.3 MATERIALS, PARAGRAPH 6. Roofing Materials, "a. Concrete roof coating" to "a. Energy Star coated foamed roofing shall be installed on concrete roof by roofing subcontractor per Section 07 57 00 Coated Foamed Roofing".
- *Note:* Refer to Section 07 57 00 Coated Foamed Roofing, except this coating is to be applied directly on the concrete roof deck and no walkway pads are required. Contractor has the option of wrapping the edge of the deck with the polyurethane coating; or applying a sheet metal fascia deep enough to cover the edge of the 4" deep concrete roof deck and have a metal drip at the bottom edge of the fascia. The polyurethane coating only needs to be as thick as required to achieve the Energy Star rating. (This applies to the ARFF and the West Vault.)



Carla L. Marley
February 6, 2012

ATTACHMENT A TO ADDENDUM NO. 6

Acknowledgement of Receipt of Addendum No. 6

**CITY OF SAN ANTONIO
AVIATION DEPARTMENT**

RECEIPT OF ADDENDUM NO. 6 IS HEREBY ACKNOWLEDGED FOR PLANS AND

SPECIFICATIONS FOR CONSTRUCTION OF San Antonio International Airport IT Infrastructure
Modernization – 33-00048

FOR WHICH BIDS WILL BE OPENED ON Tuesday, February 14, 2012 at 2:00 p.m.

THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH THE BID
PACKAGE.

Company Name: _____

Address: _____

City/State/Zip Code: _____

Date: _____

Signature

Print Name/Title